



C NO: 102/2021

Office of the Station Officer
Fire and Rescue Station
Nedumangad
Dtd:24/04/2026

From,

Station Officer
Fire and rescue Station
Nedumangad

To,

The Principal/Manager
Crescent Central School
(Affiliated to CBSE Delhi)
Peringammala 695563
Thiruvananthapuram

Sub: Fire and Rescue Station Nedumangad:- Fire Approval
(Installation work as per NBC Part IV Life safety
certificate issuing -Inspection- Reg.,

Ref: (1) Your Letter Dtd:22/03/2026

(2) Orde no F2-9400/16 Dtd:16/04/2019 Of Director General,
Fire & Rescue Services, HQ TVPM

Vide reference cited (1) The Crescent Central English
Medium School (Affiliated to CBSE Delhi) Peringammala 695563
Thiruvananthapuram District, I inspected 24/04/2026 in this school as per
National Building Code according to part four Life safety Fixed fire fighting
installations work (Fire stair ,10000 ltr Top water tank, Pump, Pipeline, Hose
reel hose , Fire Extinguisher etc) is progressing very well .



Yours Faithfully

സ്റ്റേഷൻ ഓഫീസർ
ഫയർ ആൻഡ് റെസ്ക്വ് സർവീസ്
നെടുമംഗാട്
പിൻ - 69 5541