



QUALITY CONTROL DISTRICT LABORATORY KERALA WATER AUTHORITY

Vellayambalam, Thiruvananthapuram – 695033
Tel: 04712992303; e-mail: aeqcdltvm@gmail.com



TEST REPORT

ULR No: TC1216426000002382F

Test Report No: 2026/QCDL/TVM/2382

Date: 03.07.2026

Customer Name & Address: PRINCIPAL, CRESCENT SCHOOL PALODE PANGODE P O PERINGAMALA	
Phone Number : 9446363255	
Date of collection: 24.06.2026	Sampling was done by: The Customer (QUA_358740)
Sample code: 2026/QCDL/TVM/2382	Sample particulars: Drinking Water
Sample quantity: 250 ml	Date of analysis: From: 24.06.2026 To: 26.06.2026

Sl. No	Parameters	Acceptable limits as per IS-10500-2012	Test Method	Result
1	Total Coliform	Shall not be detected / 100ml	IS 15185 Membrane Filtration Method	PRESENT / 100 ml
2	<i>E. coli</i>	Shall not be detected / 100ml	IS 15185 Membrane Filtration Method	PRESENT / 100 ml

Remarks:

- The results apply to the sample as received for testing.
- This test report shall not be reproduced except in full without the written approval of the laboratory management.



Analyzed by

Authorized Signatory

End of the report

BACTERIOLOGIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
THIRUVANANTHAPURAM

QCDL/TR/D/7.8/A	Issue No: 3	Issue Date: 26.10.2023
Rev. No: 04	Rev. Date: 07.01.2026	Page 1 of 1