

FITNESS CERTIFICATE

To be filled by the Inspecting Officer (Asst. Engineer)

(Re: G.O. Ms. 20/70/ PWD Dt. 23 - 01 -1970)

52/AE/LID&LW/PMLA/26-27

1. Name of the Officer
2. Name of the School
3. Location with name of Education District/ Sub. District
4. Classification of Building as specified in column 4 of the application for fitness certificate and size.

Shamrad J
Crescent Central School
Perungode (P.O.) Peringammala

Permanent Rcc building
34.00 m x 8.70 m x 3.70 m x 4 floors
12.50 m x 9.20 m x 3.70 m x 4 floors

5. Period for which the certificate is issued
6. Nature of defects , if any
 - a) Foundation and basement
 - b) Superstructure
 - c) Doors and Windows
 - d) Wood work wrought and put up
 - e) Roof
 - f) Flooring
 - g) Miscellaneous (Cracks, etc.)
7. Any major defects noticed which will render the building unsafe in any manner

2026-27

NIL

The back side of the shades are broken
urgent plastering is necessary within 3 months

NIL

Some cracks seen, that are test fixed

* The back side and left side of the
building plastering is necessary and
should be completed within 3 months.

Yes, the structure is sound under normal
weather condition

Note : 1. The stability of the structure should be examined also with reference to location, altitude, intensity of wind, exposure of flood etc. 2. Any additional observations if deemed necessary for the certificate may be furnished separately with this certificate.

The structure is sound under normal weather conditions for 2026-27 Academic
year for the reason stated above.

CERTIFICATE

certified that the school building was inspected by me on 10/09/2026 and
found to be fit / ~~unfit~~ to conduct classes, for the period 2026-27 Academic year only for the
reasons stated above.

Place : Peringammala

Date : 22/09/2026



ASSISTANT ENGINEER
Local Self Government
Peringammala Grama panchayat